

Project Name Midway Community Centre
 Cover Project # 21163
 Client Project # N/A
 Date August 14, 2023



ADDENDUM NO.4

From:

Architectural Cover Anne-Frederique Paradis anef@coverac.ca 250-551-7364

Recipient:

<input checked="" type="checkbox"/>	Owner	The Village of Midway	Wendy Higashi	whigashioffice@gmail.com	250-443-1750
<input type="checkbox"/>	Discipline	Company Name	First Name Last Name	address@email.com	000-000-0000
<input type="checkbox"/>	Discipline	Company Name	First Name Last Name	address@email.com	000-000-0000
<input type="checkbox"/>	Discipline	Company Name	First Name Last Name	address@email.com	000-000-0000
<input type="checkbox"/>	Discipline	Company Name	First Name Last Name	address@email.com	000-000-0000

The following information supplements and/or supersedes the bid documents. This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form.

Description

3.0 Questions/Answers:

- Q1 The door schedule shows one countertop shutter, but it looks like there are supposed to be 2 shutters. I just want to clarify the quantity.
- A1 There is only one new shutter which is for the commercial kitchen, the other shutter on the main floor is existing and will not be replaced.
- Q2 The door schedule shows a fire rating for the countertop shutter, but the specs call for a regular non-rated shutter. Obviously, a fire rated shutter is more costly.
- A2 The new O/H shutter door does not need to be fire rated.
- Q3 If a fire rated shutter is required, would you like activation to be by local fusible link or by a solenoid release that can be connected to a fire alarm system (connection to alarm system by others)
- A3 The shutter is not required to be fire rated.

- Q4 The specs show that the countertop shutter is to be constructed of stainless steel. Stainless steel is expensive, so I'm just trying to see if this is necessary, or would either a galvanized steel shutter with the choice of standard colours white, tan, grey or brown would work, or a Clear Anodized Aluminum (non-fire rated only) shutter would work?
- A4 Refer to spec. section 08 11 00 Metal Doors and Frames Part 2 (2.1) for door material.
- Q5 Lastly, the specs call for a countertop. We do not supply and install countertops, despite the fact that the manufacture may offer countertops.
- A5 This project requires countertops, general contractor is to source them and install.

Issued by the Consultant

Anne-Frederique Paradis



2023-08-14

Name

Signature

Date