

# 2025 Annual Water Report



**Contents**

Introduction ..... 3

Midway Water Distribution System ..... 3

Reservoir ..... 4

Distribution System ..... 4

Pump Stations ..... 4

Routine Maintenance Program ..... 4

Distribution System ..... 4

Reservoir ..... 4

Pump Stations ..... 4

Water Consumption ..... 5

Water Sampling and Testing ..... 6

Bacteriological ..... 6

Full Spectrum Analysis ..... 6

Cross Connection Program ..... 6

Emergency Response Plan ..... 6

Wellhead Protection Plan ..... 6

Appendix A ..... 7

Appendix B ..... 10

## Introduction:


Under the terms of the Village of Midway Operating Permit the Village is required to provide an annual report to users of the system that provides an overview of the water system, and a summary of water test results, maintenance and improvements made to the system. All water suppliers are required to provide a similar annual report to their users.

This report has been submitted to Interior Health and is posted on the Village of Midway website. [www.midwaybc.ca](http://www.midwaybc.ca)

## Midway Water Distribution System:

The Village of Midway has approximately 278 residential and 22 commercial water connections serving the residents of Midway. These users primarily get their drinking water from 2 wells.

As part of the water distribution system the Village maintains 17 km of water main, 1 reservoir and 2 pump stations. Figure 1 shows the layout of the Village's water distribution system



## Village of Midway Water Distribution System

### **Reservoir:**

The Village has one reservoir located on the north side of Hwy 3, just above town.

The reservoir is a concrete underground tank that holds 245,000 imperial gallons of water. The tank was constructed in 1995.

### **Distribution System:**

The Village's 17 km distribution system is made up of a combination of PVC piping ranging in size from 37mm to 300mm in diameter. There are 64 fire hydrants, 87 isolation valves, 2 prvs, 1 creek crossing and 1 bridge crossing. System pressure ranges from 72psi – 95psi. The majority of the system was installed between 1995 and 1996.

### **Pump Stations:**

The Village has 3 pump stations. 2 of which are tied into the distribution system. The #1 pump house is our main lift station. This well is 96.7' deep with a 60hp pump supplying the system at a rate of 720 imp gal per min. This pump is used in the warmer months when the demand for water is high. #2 pump house is 65' deep with a 10hp pump supplying the system at a rate of 100 imp gal per min. This pump is used in the winter months when the demand for water is low. In case of a power outage the Village has a back up generator for the #2 pump house.

## **Routine Maintenance Program**

### **Distribution System:**

Fire hydrants are inspected annually and completely tore down once every five years. The distribution system is flushed twice a year, once in the spring and again in the fall. Dead-ends are flushed quarterly. All isolation valves are exercised annually to make sure they are operating properly.

### **Reservoir:**

The reservoir is inspected monthly to make sure the site and structure is secure. The isolation valves are exercised annually. The reservoir is drained, inspected, and cleaned every 5 years.


### **Pump Stations:**

Pump stations are inspected daily. A complete run through of all valves, alarms and procedures are done annually. Pump station maintenance is done every 5 years.


**Water Consumption:**

In 2025, the Village of Midway’s water consumption was 62,597,969 imp gal (284,576 m<sup>3</sup>). The daily average in the fall/winter months (Jan – Mar & Oct – Dec) is 48,101 imp gal per day (218.67 m<sup>3</sup>) and in the spring/summer months (Apr – Sept) it is 293,146 imp gal per day (1,332.67 m<sup>3</sup>). Before bringing in a watering bylaw the average daily use in the summer months were double what they are now.

**Monthly Water Consumption**  
Water Treated m<sup>3</sup>



**Annual Water Consumption**  
Water Treated m<sup>3</sup>



**Water Sampling and Testing:**

**Bacteriological:**

As required by the Interior Health Authority (IHA), Village staff takes weekly samples of the water for bacteriological testing for total Coliforms and e-Coli bacteria. There are two different sampling sites used in the Village. In addition, water samples are taken from within project areas after any work on infrastructure.

See Appendix A for 2025 test results.

**Full Spectrum Analysis:**

Every two years, Village staff also sends samples from the source water for a full spectrum analysis. Parameters such as alkalinity, metals, pH, turbidity, hardness, and disinfection byproducts are tested.

See Appendix B for 2024 test results for Well #1 and Well #2.

**Cross Connection Program:**

The Village is developing a Cross Connection Control Program to address the potential for the water system to be compromised by high-risk service connections that could introduce contaminated water into the Village's water system.

**Emergency Response Plan:**

The Village has an Emergency Response Plan pertaining to the water system. The Emergency Response Plan identifies several potential emergencies that could occur and provides a systematic approach on how the Village will deal with the emergency. The plan is available for public viewing at the Village office.

**Wellhead Protection Plan:**

The Village has completed Phase II.

**Appendix A:  
Medical Clinic**

<b>Sample Date</b>	<b>Coliform</b>	<b>E. Coli</b>	<b>Turbidity</b>	<b>Arsenic</b>
6-Jan-25	< 1	< 1	< 0.10	
13-Jan-25	< 1	< 1	< 0.10	
20-Jan-25	< 1	< 1	0.15	0.00780
27-Jan-25	< 1	< 1	< 0.10	
3-Feb-25	< 1	< 1	< 0.10	
10-Feb-25	< 1	< 1	< 0.10	
24-Feb-25	< 1	< 1	0.20	
3-Mar-25	< 1	< 1	< 0.10	
10-Mar-25	< 1	< 1	< 0.10	
17-Mar-25	< 1	< 1	< 0.10	
24-Mar-25	< 1	< 1	< 0.10	
31-Mar-25	< 1	< 1	< 0.10	
7-Apr-25	< 1	< 1	< 0.10	
28-Apr-25	< 1	< 1	< 0.10	
5-May-25	< 1	< 1	0.10	
12-May-25	< 1	< 1	< 0.10	
26-May-25	< 1	< 1	< 0.10	
2-Jun-25	< 1	< 1	0.13	
9-Jun-25			< 0.10	
16-Jun-25	< 1	< 1	< 0.10	0.00652
23-Jun-25	< 1	< 1	< 0.10	
7-Jul-25	< 1	< 1	< 0.10	
14-Jul-25	< 1	< 1	< 0.10	
21-Jul-25	< 1	< 1	0.19	
28-Jul-25	< 1	< 1	< 0.10	
11-Aug-25	< 1	< 1	< 0.10	0.00679
18-Aug-25	< 1	< 1	< 0.10	
25-Aug-25	< 1	< 1	< 0.10	
15-Sept-25	< 1	< 1	< 0.10	
22-Sept-25	< 1	< 1	< 0.10	
6-Oct-25	< 1	< 1	< 0.10	
20-Oct-25	< 1	< 1	< 0.10	
27-Oct-25	< 1	< 1	0.11	
3-Nov-25	< 1	< 1	< 0.10	0.00719
17-Nov-25	< 1	< 1	0.20	
8-Dec-25	< 1	< 1	< 0.10	
15-Dec-25	< 1	< 1	0.12	


## Community Centre

Sample Date	Coliform	E. Coli	Turbidity
6-Jan-25	< 1	< 1	
13-Jan-25	< 1	< 1	
20-Jan-25	< 1	< 1	
27-Jan-25	< 1	< 1	
3-Feb-25	< 1	< 1	
10-Feb-25	< 1	< 1	
24-Feb-25	< 1	< 1	
3-Mar-25	< 1	< 1	
10-Mar-25	< 1	< 1	
17-Mar-25	< 1	< 1	
24-Mar-25	< 1	< 1	
31-Mar-25	< 1	< 1	
7-Apr-25	< 1	< 1	
28-Apr-25	< 1	< 1	
5-May-25	< 1	< 1	
26-May-25	< 1	< 1	
2-Jun-25	< 1	< 1	
16-Jun-25	< 1	< 1	
7-Jul-25	< 1	< 1	
14-Jul-25	< 1	< 1	
21-Jul-25	< 1	< 1	
15-Sept-25	< 1	< 1	
6-Oct-25	3	< 1	
20-Oct-25	< 1	< 1	
27-Oct-25	< 1	< 1	

## Well/Pumphouse #2

Sample Date	Coliform	E. Coli	Turbidity	Background Colonies
23-Jun-25	< 1	< 1		
28-Jul-25	< 1	< 1		
11-Aug-25	< 1	< 1		
18-Aug-25	< 1	< 1		
25-Aug-25	< 1	< 1		
22-Sept-25	< 1	< 1		
3-Nov-25	6	< 1		
17-Nov-25	< 1	< 1		
8-Dec-25	< 1	< 1		
15-Dec-25	< 1	< 1		

Appendix B:




TEST RESULTS

REPORTED TO PROJECT Midway, Corporation of the Village of Drinking Water

WORK ORDER REPORTED 24D1053 2024-04-15 14:07

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
<b>Well #1 (24D1053-01)   Matrix: Water   Sampled: 2024-04-08 09:30</b>					
<b>Anions</b>					
Chloride	8.92	AO ≤ 250	0.10 mg/L	2024-04-10	
Fluoride	0.66	MAC = 1.5	0.10 mg/L	2024-04-10	
Nitrate (as N)	0.992	MAC = 10	0.010 mg/L	2024-04-10	
Nitrite (as N)	< 0.010	MAC = 1	0.010 mg/L	2024-04-10	
Sulfate	41.9	AO ≤ 500	1.0 mg/L	2024-04-10	
<b>Calculated Parameters</b>					
Hardness, Total (as CaCO3)	200	None Required	0.500 mg/L	N/A	
Langelier Index	0.09	N/A	-5.0	2024-04-15	CT6
Solids, Total Dissolved	264	AO ≤ 500	1.00 mg/L	N/A	
<b>General Parameters</b>					
Alkalinity, Total (as CaCO3)	188	N/A	1.0 mg/L	2024-04-10	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-10	
Alkalinity, Bicarbonate (as CaCO3)	188	N/A	1.0 mg/L	2024-04-10	
Alkalinity, Carbonate (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-10	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-10	
Colour, True	< 5.0	AO ≤ 15	5.0 CU	2024-04-10	
Conductivity (EC)	445	N/A	2.0 µS/cm	2024-04-10	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020 mg/L	2024-04-10	
pH	7.74	7.0-10.5	0.10 pH units	2024-04-10	HT2
Temperature, at pH	20.4	N/A	°C	2024-04-10	HT2
Turbidity	0.54	OG < 1	0.10 NTU	2024-04-10	
<b>Microbiological Parameters</b>					
Coliforms, Total	< 1	MAC = 0	1 CFU/100 mL	2024-04-09	
E. coli	< 1	MAC = 0	1 CFU/100 mL	2024-04-09	
<b>Total Metals</b>					
Aluminum, total	< 0.0050	OG < 0.1	0.0050 mg/L	2024-04-12	
Antimony, total	< 0.00020	MAC = 0.006	0.00020 mg/L	2024-04-12	
Arsenic, total	0.0116	MAC = 0.01	0.00050 mg/L	2024-04-12	
Barium, total	0.0352	MAC = 2	0.0050 mg/L	2024-04-12	
Boron, total	< 0.0500	MAC = 5	0.0500 mg/L	2024-04-12	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010 mg/L	2024-04-12	
Calcium, total	48.4	None Required	0.20 mg/L	2024-04-12	
Chromium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2024-04-12	
Cobalt, total	< 0.00010	N/A	0.00010 mg/L	2024-04-12	
Copper, total	0.00127	MAC = 2	0.00040 mg/L	2024-04-12	
Iron, total	0.054	AO ≤ 0.3	0.010 mg/L	2024-04-12	
Lead, total	0.00108	MAC = 0.005	0.00020 mg/L	2024-04-12	
Magnesium, total	19.0	None Required	0.010 mg/L	2024-04-12	
Manganese, total	0.00160	MAC = 0.12	0.00020 mg/L	2024-04-12	
Mercury, total	< 0.000010	MAC = 0.001	0.000010 mg/L	2024-04-10	



## TEST RESULTS

**REPORTED TO PROJECT** Midway, Corporation of the Village of Drinking Water

**WORK ORDER REPORTED** 24D1053  
2024-04-15 14:07

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
<b>Well #1 (24D1053-01)   Matrix: Water   Sampled: 2024-04-08 09:30, Continued</b>					
<i>Total Metals, Continued</i>					
Molybdenum, total	0.00566	N/A	0.00010 mg/L	2024-04-12	
Nickel, total	< 0.00040	N/A	0.00040 mg/L	2024-04-12	
Potassium, total	2.40	N/A	0.10 mg/L	2024-04-12	
Selenium, total	< 0.00050	MAC = 0.05	0.00050 mg/L	2024-04-12	
Sodium, total	23.6	AO ≤ 200	0.10 mg/L	2024-04-12	
Strontium, total	1.36	MAC = 7	0.0010 mg/L	2024-04-12	
Uranium, total	0.00676	MAC = 0.02	0.000020 mg/L	2024-04-12	
Zinc, total	< 0.0040	AO ≤ 5	0.0040 mg/L	2024-04-12	

**Sample Qualifiers:**

CT6 Results were based on lab temperature & lab pH.  
 HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.



## TEST RESULTS

**REPORTED TO PROJECT** Midway, Corporation of the Village of Drinking Water

**WORK ORDER REPORTED** 24D2826  
2024-04-29 13:25

Analyte	Result	Guideline	RL Units	Analyzed	Qualifier
<b>Well #2 (24D2826-01)   Matrix: Water   Sampled: 2024-04-22 09:30</b>					
<b>Anions</b>					
Chloride	8.58	AO ≤ 250	0.10 mg/L	2024-04-24	
Fluoride	0.50	MAC = 1.5	0.10 mg/L	2024-04-24	
Nitrate (as N)	3.52	MAC = 10	0.010 mg/L	2024-04-24	
Nitrite (as N)	< 0.010	MAC = 1	0.010 mg/L	2024-04-24	
Sulfate	21.5	AO ≤ 500	1.0 mg/L	2024-04-24	
<b>Calculated Parameters</b>					
Hardness, Total (as CaCO3)	196	None Required	0.500 mg/L	N/A	
Langelier Index	0.09	N/A	-5.0	2024-04-29	CT6
Solids, Total Dissolved	229	AO ≤ 500	1.00 mg/L	N/A	
<b>General Parameters</b>					
Alkalinity, Total (as CaCO3)	161	N/A	1.0 mg/L	2024-04-25	
Alkalinity, Phenolphthalein (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-25	
Alkalinity, Bicarbonate (as CaCO3)	161	N/A	1.0 mg/L	2024-04-25	
Alkalinity, Carbonate (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-25	
Alkalinity, Hydroxide (as CaCO3)	< 1.0	N/A	1.0 mg/L	2024-04-25	
Colour, True	< 5.0	AO ≤ 15	5.0 CU	2024-04-24	
Conductivity (EC)	381	N/A	2.0 µS/cm	2024-04-25	
Cyanide, Total	< 0.0020	MAC = 0.2	0.0020 mg/L	2024-04-26	
pH	7.70	7.0-10.5	0.10 pH units	2024-04-25	HT2
Temperature, at pH	21.5	N/A	°C	2024-04-25	HT2
Turbidity	0.12	OG < 1	0.10 NTU	2024-04-25	
<b>Microbiological Parameters</b>					
Coliforms, Total	< 1	MAC = 0	1 CFU/100 mL	2024-04-23	
E. coli	< 1	MAC = 0	1 CFU/100 mL	2024-04-23	
<b>Total Metals</b>					
Aluminum, total	< 0.0050	OG < 0.1	0.0050 mg/L	2024-04-27	
Antimony, total	< 0.00020	MAC = 0.006	0.00020 mg/L	2024-04-27	
Arsenic, total	0.00411	MAC = 0.01	0.00050 mg/L	2024-04-27	
Barium, total	0.0309	MAC = 2	0.0050 mg/L	2024-04-27	
Boron, total	< 0.0500	MAC = 5	0.0500 mg/L	2024-04-27	
Cadmium, total	< 0.000010	MAC = 0.007	0.000010 mg/L	2024-04-27	
Calcium, total	59.3	None Required	0.20 mg/L	2024-04-27	
Chromium, total	0.00089	MAC = 0.05	0.00050 mg/L	2024-04-27	
Cobalt, total	< 0.00010	N/A	0.00010 mg/L	2024-04-27	
Copper, total	0.00057	MAC = 2	0.00040 mg/L	2024-04-27	
Iron, total	< 0.010	AO ≤ 0.3	0.010 mg/L	2024-04-27	
Lead, total	< 0.00020	MAC = 0.005	0.00020 mg/L	2024-04-27	
Magnesium, total	11.6	None Required	0.010 mg/L	2024-04-27	
Manganese, total	< 0.00020	MAC = 0.12	0.00020 mg/L	2024-04-27	
Mercury, total	< 0.000010	MAC = 0.001	0.000010 mg/L	2024-04-25	



## TEST RESULTS

**REPORTED TO PROJECT** Midway, Corporation of the Village of Drinking Water

**WORK ORDER REPORTED** 24D2826  
2024-04-29 13:25

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
<b>Well #2 (24D2826-01)   Matrix: Water   Sampled: 2024-04-22 09:30, Continued</b>						
<i>Total Metals, Continued</i>						
Molybdenum, total	0.00248	N/A	0.00010	mg/L	2024-04-27	
Nickel, total	< 0.00040	N/A	0.00040	mg/L	2024-04-27	
Potassium, total	2.27	N/A	0.10	mg/L	2024-04-27	
Selenium, total	0.00059	MAC = 0.05	0.00050	mg/L	2024-04-27	
Sodium, total	11.7	AO ≤ 200	0.10	mg/L	2024-04-27	
Strontium, total	0.552	MAC = 7	0.0010	mg/L	2024-04-27	
Uranium, total	0.00557	MAC = 0.02	0.000020	mg/L	2024-04-27	
Zinc, total	< 0.0040	AO ≤ 5	0.0040	mg/L	2024-04-27	

**Sample Qualifiers:**

CT6 Results were based on lab temperature & lab pH.  
 HT2 The 15 minute recommended holding time (from sampling to analysis) has been exceeded - field analysis is recommended.